



HITECH FIRE SAFETY ENGINEERING

3/123, Rugmini, Kumarapuram,
Ambikapuram (Post), Palakkad - 678 011
Ph : 8089382834, 8714339931
E-mail : hitechfiresafety27@gmail.com

Ref: HFS-108/21

Date: 02.05.2021

TO WHOMSOEVER IT MAY CONCERN

We hereby certify that we have installed the following fire Protection System consisting of the following items at Darul Aman English Medium High School, Kalladikode, Palakkad, Kerala.

- | | |
|-----------------------|--------|
| 1. Hose Reel Drum | 8 nos. |
| 2. 5hp electric motor | 1 no. |
| 3. Fire Extinguishers | 8 nos |
| 4. Fire Brignde inlet | 1 no. |

Fire extinguisher refilling date : 13.1.2021

Fire extinguisher expiry date : 12.1.2022

All the equipments installed were confirming to The National Building Code of India 2016 (NBC)

We also certify that all the systems are tested and is in good working condition.

For HITECH FIRE SAFETY ENGINEERING


Authorized Signatory





PRINCIPAL
DARUL AMAN ENGLISH MEDIUM SCHOOL

(Senior Secondary)

Aff. No 930327

Kalladikode, Palakkad Dt.


MANAGER

Darul Aman English Medium
Senior Secondary School
CBSE Aft. No:930327
Kalladikode, Palakkad - 678 596

FIRE SAFETY CONSULTANT & ENGINEERS

FIRE ALARMS, FIRE HYDRANTS, SPRINKLERS, FIRE EXTINGUISHER Etc.

Supply & Maintenance of the fire fighting equipments

