

Ref No: KP/S 025/21

**SANITARY CERTIFICATE**

\*\*\*\*\*

As Per the Govt. Notification No:1054/G3/79HD.Dated 27<sup>th</sup> June 1979 I, Health Officer of Karimba Grama Panchayath area do here by certify that the 'Darul amen English Medium School' and its premises at Kalladikode moppila school jn of Karimba Grama Panchayat, run by *Darul amen Islamic Complex kalladikode P O* Inspected by me and the arrangements made at present for driking water and sanitary purpose are satisfactory. Hence a sanitary fitness certificate is issued to run the unit subject to the condition laid down in the order, any violation of any one of the conditions will automatically invalidate this certificate.

This certificate is issued subject to the conditions found on inspection on 05.04.21

~~This Certificate issued only for the purpose of licence from karimba Gramapanchayat and valid up to (31.03.2022)~~ *Valid up to 31/03/2022*

Kalladikode

06.04.21



*[Signature]*  
Health Inspector  
PHC Kalladikode  
Health Inspector  
Primary Health Cent  
Kalladikode - 678 596

*[Signature]*  
**PRINCIPAL**  
**DARUL AMAN ENGLISH MEDIUM SCHOOL**  
(Senior Secondary)  
Aff. No 930327  
Kalladikode, Palakkad Dt.



*[Signature]*  
**MANAGER**  
**Darul Aman English Medium**  
**Senior Secondary S.**  
**CBSE Aft. No:930327**  
**Kalladikode, Palakkad - 678 596**

Telephone: 0491-2545550


email:-qcdlkwapkd@gmail.com



**KERALA WATER AUTHORITY  
QUALITY CONTROL DISTRICT LAB, PALAKKAD-678001  
WATER TEST REPORT**

Report No:PKD/28		Report Issue Date : 15-07-2021			
Customer Name & Address		Date of Receipt	06-07-2021		
Darul Aman English Medium School, Kalladikkode.		Sampling Done by	CUSTOMER		
		Sample Name	WATER		
		Sample Condition	GOOD		
		Sample Code	PKD/2493		
		Source of Sample	Open Well		
		Sample Quantity	2.LITRE		
		Test performing date	from 07/07/2021 to 09/07/2021		
Sl.No	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Colour	CU	IS 3025 (Part 4)-1983(Reaffirmed 2017)	5.0000	5
2	Turbidity	(NTU)	IS 3025 (Part10)-1984(Reaffirmed 2017)	1.00	0.28
3	pH- C	-	IS 3025 (Part 11)-1983(Reaffirmed 2017)	6.5 to 8.5	4.38
4	Electrical conductivity at 25- C	(micromhos/cm)	IS 3025 (Part 14)-2013(Reaffirmed 2019)	-	176.8
5	Acidity	(mg/litre)	IS 3025 (Part 22)-1986(Reaffirmed 2019)	-	16
6	Alkalinity	(mg/litre)	IS 3025 (Part 23)-1986(Reaffirmed 2019)	200.00	8.24
7	Sulphate (as SO4)	(mg/litre)	IS 3025 (Part 24)-1984(Reaffirmed 2017)	250.00	1.50
8	Total Dissolved Solids (TDS)	(mg/litre)	IS 3025 (Part 16)-1984(Reaffirmed 2017)	500.00	102.4
9	Total Hardness (as CaCO3)	(mg/litre)	IS 3025 (Part21)-2009(Reaffirmed 2019)	200.00	18.9
10	Calcium (as Ca)	(mg/litre)	IS 3025 (Part 40)-1991(Reaffirmed 2019)	75.00	5.88
11	Magnesium (as Mg)	(mg/litre)	IS 3025 (Part 46)-1994(Reaffirmed 2019)	30.00	1.02
12	Chloride (as Cl)	(mg/litre)	IS 3025 (Part 32)-1988(Reaffirmed 2019)	250.00	34.34
13	Fluoride (as F)	(mg/litre)	IS 3025 (Part 60)-2008(Reaffirmed 2013)	1.00	0.01
14	Iron (as Fe)	(mg/litre)	IS 3025 (Part 53)-2003(Reaffirmed 2014)	1.00	0.16
15	Nitrate (as NO3)	(mg/litre)	APHA Method	45.00	21.66
Remarks :-					
NB:- 1. The result stated above related only to the sample(s) submitted for testing .					
2. The samples retain for 15 days from the date of issue.					
3. The test certificate shall not be reproduced except in full without the written approval of the Laboratory.					
Analysed by				Authorized by	
KWA/QCDL/PKD /10-2020		Issue : 1		Issue Date : 15/07/2020	
Ref No:Nil		Rev,Date :Nil		Page 1 of 2	
End of Report					

**PRINCIPAL**  
**DARUL AMAN ENGLISH MEDIUM SCHOOL**  
(Senior Secondary)  
Aff. No 930327  
Kalladikkode, Palakkad Dt.



*Waleesh duley*  
**MANAGER**  
**Darul Aman English Medium**  
**Senior Secondary School**  
**CBSE Aff. No:930327**  
**Kalladikkode, Palakkad - 678 596**



**KERALA WATER AUTHORITY**  
**QUALITY CONTROL DISTRICT LAB, PALAKKAD-678001**  
**WATER TEST REPORT**

Report No: PKD/28		Report Issue Date : 15-07-2021	
Customer Name & Address		Date of Receipt	06-08-2021
Darul Aman English Medium School, Kalladikkode.		Sampling Done by	CUSTOMER
		Sample Name	WATER
		Sample Condition	GOOD
		Sample Code	PKD/2493
		Source of Sample	Open Well
		Sample Quantity	100ml
		Test performing date	from
Sl. No.	Source	No of Coliforms per 100ml of sample	E.Coli in 100ml of sample
1	Water sample submitted by the customer	Absent	Nil


Remarks :-

- NB:- 1. The result stated above related only to the sample(s) submitted for testing .  
2. The samples retain for 15 days from the date of issue.  
3. The test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Analyzed by

Authorized by

KWA/QCDL/PKD/10-2020	Issue : 1		Issue Date : 13/10/2020
Ref No: Nil	Rev, Date : Nil	Page 2 of 2	Chemist
End of Report			Quality Control District Lab, KWA Kallandapam, Palakkad



**PRINCIPAL**  
**DARUL AMAN ENGLISH MEDIUM SCHOOL**  
(Senior Secondary)  
Aff. No 930327  
Kalladikkode, Palakkad Dt.



**MANAGER**  
**Darul Aman English Medium**  
**Senior Secondary School**  
**CBSE Aft. No: 930327**  
**Kalladikkode, Palakkad - 678 596**